

"STOP CORONA VIRUS Wash Your Hand/Wear Mask/Maintain Social Distance"



**DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY
WATER TREATMENT PLANT NANGLOI, DELHI-110041**



Water sample collected from M/S Sushil International School, Pandwala Kalan, Main Ghumanhera Road, Najafgarh, New Delhi 110043 Vide Challan No 224 dated 27.10.2025.

S. No.	Particulars	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	--	--	--	29.10.2025
2.	Date of analysis	--	--	--	30.10.2025
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	--	No Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	0.5
6.	PH value	--	6.5	8.5	4.5
7.	Electrical Conductivity	µmho	--	--	Nil
8.	Total dissolved solids	mg/l	500	2000	430
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	mg/l	--	--	Nil
10.	Total Alkalinity	mg/l	200	600	130
11.	Total Hardness	mg/l	200	600	150
12.	Calcium Hardness	mg/l	--	--	Nil
13.	Magnesium Hardness	mg/l	--	--	Nil
14.	Calcium as Ca	mg/l	75	200	50
15.	Magnesium as Mg	mg/l	30	100	15
16.	Ammonia as N	mg/l	0.5	N.R.	0.3
17.	Nitrite as N	mg/l	--	--	Nil
18.	Nitrate as NO ₃	mg/l	45	N.R.	15
19.	Sulphate	mg/l	200	400	110
20.	Chloride	mg/l	250	1000	125
21.	Dissolved Iron	mg/l	0.3	N.R.	0.1
22.	Fluoride	mg/l	1	1.5	0.01
23.	Cyanide	mg/l	0.05	N.R.	<0.001
24.	Residual Chlorine	mg/l	0.20	1.0	0.1
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0	0	0


REMARKS: On the basis of above tested parameters, the sample S-1 can be use for drinking purpose.

ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works, Nangloi, Delhi-41

Chemist



MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2025/D- 1731

Dated 04/03/2025

1. Name of the School: - SUSHIL INTERNATIONAL SCHOOL
2. SCHOOL ADDRESS - Hans Nagar Aashram Colony, Main Ghumanhera Road, Najafgarh New Delhi-110043
3. NO. OF SHIFT ONE TIMING Morning. 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: BOYS - 285 GIRLS - 150 TOTAL = 435
5. NO. OF STAFFS: MALE -05 FEMALE - 23 TOTAL = 28

Details of Accommodations present in School

- | | |
|---|-------------------------------------|
| 1. Floor Space in the Classroom Sufficient/insufficient | SUFFICIENT |
| 2. The Classrooms are Well Lighted/ill lighted | WELL LIGHTED |
| 3. The Classrooms are Well Ventilated/ill ventilated | WELL VENTILATED |
| 4. The Classrooms are kept / Not kept Neat & Clean: | NEAT AND CLEAN |
| 5. The Building requires/does not required Whitewash etc. | NOT REQUIRED |
| 6. The Drinking Water is Wholesome/Not wholesome | WHOLESOME |
| 7. The Latrine arrangement is Sanitary/Insanitary | SANITARY FROM HEALTH POINT OF VIEW. |

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
2. One latrine for 40 male student is required so total is SUFFICIENT
3. Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
4. The Overall facilities: Good/ Adequate/Inadequate GOOD FROM HEALTH POINT OF VIEW.

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard


Deputy Health Officer
Najafgarh Zone
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)

DELHI JAL BOARD: GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
ROOM NO. 209, VARUNALAYA PHASE-I
KAROL BAGH, NEW DELHI - 110005
23558264

No./DJB/EE(RWH/GWC)/2018/ 1960
To,

DATED: 24/4/19


Principal,
Sushil International School!,
Pandwala Kalan, Near Hans Nagar Aashram,
Main Ghumenhera Road, Najafgarh, New Delhi-43

Subject:- Regarding adequacy of rain water harvesting system at Sushil International School, Pandwala Kalan, Near Hans Nagar Aashram, Main Ghumenhera Road, Najafgarh, New Delhi-43.

The above said unit has been inspected by Joint Inspection Team on 23.04.2019, constituted by Hon'ble NGT in O.A. No. 217/2016. It was found that one No. RWH pit is existing at site.

The existing RWH structure is functional and adequate to harvest the roof top run-off for catchment area of above said unit. The RWH structure is found to be functional at the time of inspection.

You are advised to keep the existing RWH system neat & clean & maintain the same periodically.


EE (RWH/GWC)
EE (G W CELL)
DELHI JAL BOARD
VARUNALAYA BHAWAN,
JHANDEWALLAN, N.D.-05